



Effects of Turbine Spacings in Very Large Wind Farms

Andersen, Søren Juhl; Sørensen, Jens Nørkær; Mikkelsen, Robert Flemming

Publication date:
2015

Document Version
Peer reviewed version

[Link back to DTU Orbit](#)

Citation (APA):
Andersen, S. J., Sørensen, J. N., & Mikkelsen, R. F. (2015). *Effects of Turbine Spacings in Very Large Wind Farms*. Abstract from 68th Annual Meeting of the American Physical Society's Division of Fluid Dynamics (DFD), Boston, United States.

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Log #DFD15-2015-000997

Abstract Submitted
for the DFD15 Meeting of
The American Physical Society

Sorting Category: 5.6 (C)

Effects of Turbine Spacing in Very Large Wind Farms.¹

SØREN JUHL ANDERSEN, JENS NØRKÆR SØRENSEN, ROBERT FLEMMING MIKKELSEN, Technical University of Denmark — The Dynamic Wake Meandering model(DWM) by Larsen et al.(2007) is considered state of the art for modelling the wake behind a wind turbine. DWM assumes a quasi-steady wake deficit transported as a passive tracer by large atmospheric scales. The approach is also applied to wake interaction within wind farms, although certain aspects of the complex wake interaction are not captured, see Churchfield et al.(2014). Recent studies have shown how turbines introduce low frequencies in the wake, which could describe some of the shortcomings. Chamorro et al.(2015) identified three regions of different lengths scales. Iungo et al.(2013) related low frequencies to the hub vortex instability. Okulov et al.(2014) found Strouhal numbers in the far wake stemming from the rotating helical vortex core. Simulations by Andersen et al.(2013) found low frequencies to be inherent in the flow inside an infinite wind farm. LES simulations of large wind farms are performed with full aero-elastic Actuator Lines. The simulations investigate the inherent dynamics inside wind farms in the absence of atmospheric turbulence compared to cases with atmospheric turbulence. Resulting low frequency structures are inherent in wind farms for certain turbine spacings and affect both power production and loads.

¹Funded by Danish Council for Strategic Research(grant 2104-09-067216/DSF), the Nordic Consortium on Optimization and Control of Wind Farms, and EuroTech wind project. The proprietary data for

Abstract Vestas' NM80 turbine has been used.*Limit*

☒ Prefer Oral Session
☐ Prefer Poster Session

SØREN JUHL ANDERSEN
sjan@dtu.dk
Technical University of Denmark

Date submitted: 29 Jul 2015

Electronic form version 1.4